State of West Virginia Source Water Assessment and Protection Program

Source Water Assessment Report

WVAWC New River District Fayette County PWSID: WV3301046



Prepared by:

West Virginia Department of Health and Human Resources Bureau for Public Health Office of Environmental Health Services Source Water Protection Unit

Date: March 2004

Surface Water Public Water Supply Systems Source Water Assessment and Protection Program (SWAPP) Susceptibility Report WVAWC – New River District November 2002 Report-R.D. Zande and Associates, Inc. March 2004 Report Revised-WV Bureau for Public Health

What Is The Purpose of a Susceptibility Report?

A susceptibility report identifies the most significant potential significant contaminant sources that could threaten the quality of the general public's water supply. A public water supply's susceptibility ranking does not indicate poor water quality. Regular testing of both the raw water and finished water best reflects actual water quality conditions. This susceptibility report will be used by the West Virginia Bureau for Public Health, hereinafter referred to as the WVBPH, and the public water supply systems to identify the quality of the source water and what techniques may be required to improve the water quality in the future. In addition, this report will enhance West Virginia's existing watershed approach to water quality improvement and protection.
 Table 1 provides you information on your public water
 supply.

PWS Name	WVAWC - New River District
PWS Address	300 Backman Rd. Rt. 2 Fayetteville, WV 25840
PWS ID Number	WV3301046
County	Fayette
System Type	Community

Table 1: Public Water Supply (PWS) Information

What Is The Source Water Assessment and Protection Program?

The Source Water Assessment and Protection Program, also known as SWAPP, was established under the Safe Drinking Water Act, requires every state in the United States to:

- Delineate the area from which a public water supply system receives its water;
- Inventory land uses within the recharge areas of all public water supplies;
- Assess the susceptibility of drinking water sources to contamination from these land uses; and
- Publicize the results to provide support for improved protection of sources.

R.D. Zande & Associates, Inc., hereinafter referred to as RDZ, in conjunction with WVBPH, is undertaking the second and third requirements of the SWAPP. The final task will be undertaken by the WVBPH upon completion of the first three (3) tasks. The rankings of susceptibility of the WVAWC - New River District's intake(s) to potential contamination are listed in **Table 2**.

Table 2: Intake Information

Facility Name	Source Name	Design Meets Regulations	Susceptibility Ranking
WVAWC - New River District	New River	Yes	High

RDZ assessed the source water treated by the WVAWC - New River District based upon three (3) sources of information. The three (3) sources that RDZ utilized were field reconnaissance, personnel interviews, and the analysis of water quality data. The data review, the personnel interviews, and the field reconnaissance were conducted within the Zone of Critical Concern, hereinafter referred to as ZCC. Upon completion of the necessary fieldwork and data review, the results were analyzed, and the findings were used to produce the assessment report. A brief summary of each of the information sources used is listed below.

• Field Reconnaissance

On the site visit that began on November 20, 2002, RDZ began conducting the field reconnaissance survey for the New River ZCC. This field reconnaissance survey consisted of the verification of existing potential significant contaminant sources, hereinafter referred to as PCSs, through the use of Global Positioning System, also known as GPS, equipment and the identification of new PCSs using GPS equipment. The GPS equipment utilized for the PCSs was the Trimble Geo Explorer III-C, which generated latitude and longitude in decimal degrees. The unit also had the ability to be differentially corrected to +/- 5 meters of accuracy. The field survey at each PCS also consisted of a minimum of 30 counts at five-second (5 sec) intervals with a position dilution of precision (PDOP) of six (6) to ensure accuracy. Four (4) existing PCSs were identified and surveyed and a total of three (3) new PCSs were identified and surveyed. After GPSing the locations of new and existing PCSs, a field information sheet, and the accompanying digital photograph(s), was completed for each PCS. This information was then transferred to a Microsoft Access database that will be provided to the WVBPH for further source water analysis.

Of the PCSs that were located and verified, 71 percent (71%) were considered a low threat to the source water. Commercial sites accounted for 57 percent (57%) of the PCSs located. Most of the commercial sites identified were located around the whitewater rafting and tourism activities that are prevalent throughout the region. The only wastewater treatment plant in the ZCC area was located in the City of Fayetteville. Field reconnaissance revealed that there was little industrial land uses found in the ZCC. In addition to field verification of existing PCS, the above information is also a result of a combination of information verification methods, including business directory research, agency database research, and a windshield survey, being conducted for the New River ZCC. Figure 2 shows the locations of the identified and surveyed PCSs.

• Personnel Interviews

Personnel interviews were conducted by RDZ on November 20, 2002 at sites where PCSs were located and at the water treatment plant in the New River ZCC. Interviews with personnel from the New River District water treatment plant indicated that both the raw water that was being used to provide the potable drinking water and the potable drinking water meet the requirements of the federal and state governments' guidelines.

PCS Photographs

Per the requirements of the contract between the WVBPH and RDZ, digital photographs were taken at both the existing and newly identified PCSs. The photographs and the Photograph Index Sheet, which will be utilized by the WVBPH in identifying the location of the PCS while in the field, will be provided to the WVBPH in a digital format upon the submittal of this report.

Inaccessible Areas

A large portion of inaccessible areas did exist in the New River ZCC that were a result of the lack of accessible roads. There were also areas that were inaccessible due to their location on private property. Some PCSs were inaccessible due to locked gates that prevented vehicular access.

Miscellaneous Notes

The majority of the commercial land uses in the New River area are centered around whitewater rafting and tourism attractions.

What Is My Source Water Protection Area (SWPA)?

Unlike ground water aquifers, which have a natural protective layer above them, all surface waters are susceptible to contamination because they are exposed at the surface and lack a protective barrier from contamination. Accidental spills, releases, sudden precipitation events that result in overland runoff, or storm sewer discharges can allow pollutants to readily enter the source water and potentially contaminant the drinking water at the intake. Because of this, the Source Water Protection Area, hereinafter referred to as the SWPA, consists of two (2) types of delineations, which include the Watershed Delineation Area and the Zone of Critical Concern.

• Watershed Delineation Area

The first type of delineation is the Watershed Delineation Area, hereinafter referred to as WSDA, which encompasses approximately 4,370,425 acres in the New River Watershed (Figure 1). The WSDA includes the entire watershed area upstream of the intake, and includes waters from the State of West Virginia and the State of Kentucky. The perimeter of the catchment area provides the water to the water treatment plant's supply intake. The WSDA for the New River area consisted mainly of commercial land uses.

• Zone of Critical Concern

The second type of delineation is the Zone of Critical Concern. Figure 2 shows the New River ZCC area, which encompasses approximately 4,140 acres. The ZCC is a corridor along streams within the WSDA that warrants a more detailed inventory and management due to its proximity to the surface source water intake and to the susceptibility to PCSs. The ZCC is calculated using a mathematical model that accounts for stream flows, gradient, and area topography. The length of the ZCC is based on a five-hour (5 hour) time of travel. The ZCC width is approximately 1,000' from each bank of the principal receiving stream (for a total width of 2,000') and 500' from each bank of each tributary (for a total width of 1,000') draining into the principal receiving stream. No agricultural areas were located in the ZCC. Most of the commercial sites found included car washes and gas stations. The geological setting for the ZCC consisted primarily of flat, wide valleys with small rolling hills.

What Is Susceptibility?

Susceptibility is a measure of the potential for contamination of a water treatment plant's intake from land uses and activities within the SWPA at concentrations that pose a concern to the general public. The purpose of the susceptibility analysis is to provide an indicator to what type of action a general public water system should take to further define and reduce susceptibility. This action may include recommendations for a more detailed inventory and assessment, additional monitoring work, or an indication of the type and intensity of source water and other protection activities needed.

The possibility of a release from PCSs is greatly reduced if best management practices, also referred to as BMPs, are utilized. However, the susceptibility determination for a particular intake does not take into account whether or not BMPs are being utilized.

Susceptibility of a drinking water intake does not mean a customer will drink contaminated water. Water suppliers protect the drinking water by monitoring and treating water supplies and using BMPs and source water protection measures to ensure that safe water is delivered to the customer's water tap.

How Was The Water Supply Susceptibility Determined?

The susceptibility of the WVAWC - New River District is based on the following components:

- Resource Characterization;
- Summary of Raw and Finished Water Quality; and
- Summary of Chemical and Biological Water Quality.

Resource Characterization

The purpose for conducting the Resource Characterization analysis of the delineated SWPA is to obtain an understanding of its physical, biological, chemical, and hydrological characteristics. The following four (4) resource characteristics were analyzed and evaluated:

- The potential for surface runoff to occur;
- The ease that surface runoff transport material can be delivered into the stream;
- The movement through the SWAP area; and
- The biological and chemical health of the surface water resource in the SWAP area.

Potential for Surface Runoff to Occur

The soil types present in the watershed area and the associated soil properties have a direct influence on the potential for surface runoff to occur. As the infiltration rate of the soil increases (that is, as more precipitation soaks in rather than running off), the contaminant loads associated with the reduced runoff should decrease. **Table 3** provides a summary of the associated soil groups.

Soil Associations	Soil Drainaga	Topographic Setting
Soli Associations	Son Dramage	Topographic Setting
ErB – Ernest	Poorly drained	Nearly level
DbC – Dekalb	Moderately drained	Nearly level
At – Atkins	Well drained	Gently sloping
Br – Brinkerton	Well drained	Gently sloping
CpB – Cookport	Moderately to Well drained	Nearly level
Me – Mine dump	Well drained	Gently sloping
WhB – Wharton	Poorly drained	Nearly level
St – Strip mine spoil	Well drained	Very steep
ShD – Shelocta	Moderately drained	Gently sloping
DsE – Dekalb and Gilpin	Well drained	Very steep
DsF – Dekalb and Gilpin	Well drained	Very steep
Ph – Philo	Well drained	Gently sloping
ShC – Shelocta	Well drained	Gently sloping
RaC – Rayne	Well drained	Gently sloping

Table 3: Summary of Soil Associations in the WSDA*

*This information is limited to the WSDA within the state boundaries of West Virginia.

Ease of Movement of Material into the Stream System (Rate of Overland Material Transport)

The size, shape, and slope of the SWAP area have a direct influence on material transported by surface runoff. In general, the longer the overland travel distance and travel time that surface runoff water has taken in order to reach a stream channel, the greater the chance the water has to deposit and filter the contaminants that may occur. **Table 4** provides an analysis of the size, shape, and slope of the New River WSDA.

Table 4: Hydrologic Setting

Size of WSDA (mi. ²)	6,828.81
Shape of WSDA	Large & Irregular
Stream Length (Main Stem) (mi.)	85
Average Watershed Slope	10 to 30%

Movement of Water through the Watershed Area

A number of physical and natural factors can influence the movement of water through the SWAP area. The pattern and development of the drainage network of the SWAP area directly influence the rate of water movement. Evaluation of the hydrologic cycle will provide an indication of the amount of annual rainfall that is absorbed into the ground or becomes runoff. Table 5 summarizes the total mileage of streams contained in the WSDA within the WV state boundary, the average stream gradient of the main stem, the average rainfall, the nearest relevant USGS stream gauge, the distance to the stream gauge, the topographic position of the stream gauge, the annual mean discharge, the high flow, and the low flow.

Review of Water Quality Data

Table 5: Movement of Water

Number of Stream Miles in	3,823
WSDA Within WV (mi.)	
Average Stream Gradient (Main	7.41 ft/mi
Stem)	
Average Rainfall (in.)	43
Nearest Relevant	03185400
USGS Stream Gauge (mi.)	New River @
- · · ·	Thurmond, WV
Distance to Relevant	5
USGS Stream Gauge (mi.)	
USGS Stream Gauge	Upstream
Topographic Position	-
Annual Mean Discharge (cfs)	6,314 (2001)
Highest Daily Mean Flow (cfs)	92,500
	(1-20-1996)
Lowest Daily Mean Flow (cfs)	808 (7-11-1988)

In order to characterize the condition of the surface water within the watershed, the available chemical and biological water quality data was obtained and reviewed. This data was collected as part of the WVBPH, and the West Virginia Department of Environmental Protection, also known as the WVDEP, implementation of the Federal Safe Drinking Water Act and Clean Water Act. Water quality data was then evaluated to help provide direct indicators to a source of contamination and to direct the focus for additional source evaluations. Additionally, immediate source water protection efforts will be identified by this review.

Available water quality data includes test results from treated drinking water, finished water, and untreated source water, also known as raw water, that was conducted by the water supplier. Additional water data, including ambient water chemistry, biological criteria, and monitoring, and habitat was also evaluated. The sampling requirements for public water systems vary depending on the type of system and the federal regulated testing requirements. As a result, the lack of water quality impacts may indicate the lack of a certain sampling measures rather than a lack of potential contamination.

Summary of Raw and Finished Water Quality Results from Public Water System

The following is a summary of water quality data for the New River District Water System of WVAWC New River's water treatment plant. The water source for the plant is surface water drawn from the New River. The new water treatment plant was placed into service in January 2001 and provided roughly 72 million gallons of clean drinking water to Fayette County residents during that year. The water provided to the service area during the past year met all the state and federal standards set for potable drinking water. Tap water samples were collected for lead and copper analysis from 62 homes in the service area. Lead was detected at 13 parts per billion (ppb), while the action level for lead is 15 ppb.

Summary of Chemical and Biological Water Quality Results from the West Virginia DEP

The following is a summary of water quality data for the WVAWC – New River District water treatment plant. The water source for the service area is surface water drawn from the New River. Test results for the past five (5) years for volatile organic compounds indicate detectable levels repeatedly for bromodichloromethane and chloroform, which had a concentration of 53.4 micrograms per liter (μ g/L). A large portion of the inorganic compounds also had detectable concentration levels; however, all of the concentration levels were below the federal and state guideline concentrations.

Summary of Other Available Chemical and Biological Water Quality Data

Water quality data from an environmental resource group was not available.

Potential Significant Contaminant Sources (PCSs):

Inventory of Potential Significant Contaminant Sources

The purpose for providing an inventory of certain types of land uses, a listing of PCSs, and activities within the SWAP area is to aid in reducing the risk posed to the general public's drinking water supply. The following provides information regarding the methodology used to generate the inventories.

The inventory portion of the SWAP consists of two (2) steps:

- The first step is the broad inventory based primarily on regulated and existing databases. The inventory consists of a general land use analysis, the identification of regulated activities in the delineated WSDAs, and an analysis of road and rail crossings adjacent to the streams in the WSDA.
- The second step is the detailed inventory of PCSs in the ZCC. The detailed source inventory is conducted to verify existing PCSs and to identify new PCSs that were not captured in the broad regulated source inventory and to field verify the PCSs in the ZCC. PCSs located during the inventory are found on Figure 2.

A detailed risk-assessment of the PCSs was beyond the scope of this survey because of minimal data and resources. Local decision makers should do the detailed risk analysis because they are better suited to make the bridge from assessment work to protective strategies. The West Virginia SWAP program can provide guidance to the decision makers and help in prioritizing the PCSs.

Summary of the Detailed Inventory

Table 6 is a summary of the detailed inventory of PCSs in the ZCC. The detailed source inventory was conducted to identify PCSs that were not identified in the existing database review and to verify the location of the PCSs within the ZCC.

•		
Potential Contaminant	Total	Percent (%)
Source	PCSs	
Agriculture	0	0

0

2

4

1

0

28.6 57.1

14.3

Table 6: Summary of PCSs within the ZCC

Transportation Network

A summary of the transportation network is shown in **Table 7**. This information can be used to aid in planning for transportation related accidents that could result in contamination of the source water in the delineated WSDA. **Table 8** is a summary of the transportation network stream crossings in the WSDA. Please note that miles of railroad tracks could be less due to decommissioning of the previously mentioned railroad tracks. In addition, the 977 stream crossings provide the opportunity for an accidental spill / release of materials to get directly into the stream drainage network. Source water protection efforts should be directed towards the establishment of an effective and efficient emergency response plan if one does not currently exist.

Residential

Municipal

Industrial

Commercial

Table 7: Transportation	n Network Summary	for WSDA*
-------------------------	-------------------	-----------

	Within 100 feet of Stream	Total
Miles of Interstate (mi.)	6.2	103.9
Miles of Primary Roads (mi.)	21.7	658.3
Miles of Secondary Roads (mi.)	2.3	81.7
Miles of Railroads (mi.)	58.3	479.5

*This information is limited to the WSDA within the state boundaries of West Virginia.

Table 8: Transportation Network Stream Crossings in the WSDA

	Interstate	Primary Roads	Secondary Roads	Railroads
Number of Stream	75	361	42	499
Crossings				

*This information is limited to the WSDA within the state boundaries of West Virginia.

• General Land Use

The general land use analysis will provide an indication of which land uses are predominate throughout the SWAP area, near the water intake, or adjacent to the rivers, streams, lakes, and reservoirs. The land use in the SWAP area is shown in **Table 9**. The total acreage contained within the New River WSDA is approximately 4,370,425 acres and the total acreage contained within the New River ZCC is approximately 4,140 acres.

LAND USE	WSDA (acres)	WSDA (%)	ZCC Area (acres)	ZCC (%)
Shrub Land	7,815.96	0.40	2.00	0.05
Woodland	1,496627.34	76.37	3,096.00	74.84
Water	22,958.15	1.17	705.45	17.05
Roads	694.77	0.04	0	0
Power Lines	2,966.57	0.15	25.80	0.62
Urban	45,113.43	2.30	132.77	3.21
Agriculture	373,820.12	19.08	136.11	3.29
Barren	6,158.20	0.31	34.92	0.84
Wetland	3,445.17	0.18	3.56	0.09

Table 9: General Land Use*

*This information is limited to the WSDA within the state boundaries of West Virginia.

SWAPP Area Assessment and Protection Activities

Analysis of the Resource Characterization and potential significant contaminant sources of the SWAP area for the WVAWC - New River District indicates that the water supply is susceptible to possible future contamination based on the following:

✓ The steep topographic setting, and the size of the WSDA present an increased potential for contamination. In addition, the 977 stream crossings provide the opportunity for an accidental release/spill of material to easily get directly into the stream drainage network. Source water protection efforts should be directed toward the establishment of an effective and efficient emergency response plan if one does not currently exist.

Recommendations:

- ✓ Protection efforts should focus on the collection of additional information on the point and non-point sources present to evaluate the risk;
- ✓ Work with the Department of Health and Human Resources, other state agencies and local officials to make sure your intake is included in local regulations and inspections efforts;
- ✓ Restrict access to the intake area and post the area with Drinking Water Protection Area signs;
- ✓ Address any biological contaminant issues; and
- ✓ Protection options need to be actively considered to further evaluate and manage all potential contaminant sources and the WVAWC – New River District public water supply should place a high priority on protecting its supply source.

NEXT STEP – SWAP Protection Plan

The next step in source water protection planning is to prepare a SWAP protection plan. The SWAP protection plan incorporates this source water delineation assessment report and three additional sections: Contingency Planning, Alternative Sources, and Management Planning.

Contingency Planning

A contingency plan documents the system's planned response to interruption of the source water supply.

Alternative Sources

Information pertaining to alternative water sources focusing on long-term source replacement should the system be required to develop a new source of water due to contamination (or other reasons). This section outlines the most likely sources that can be used as an alternate water source.

Management Planning

Management planning is the most important element of SWAP. The management plan identifies specific activities that will be pursued by the system to protect their water resources. The system will benefit by taking a proactive approach to source water protection in their watersheds. It is anticipated that most of the management effort will focus on coordination with government agencies and periodic surveys of the watersheds. It may be necessary to conduct a limited number of special studies to determine actual risk and consequences for selected contaminant sources. This information may be needed before decisions can be made on management activities.

Need additional information?

Additional information or sources of information can be obtained by calling or visiting the BPH web site at www.wvdhhr.org/bph/swap or phoning 304-558-2981.

Disclaimer - The coverage's presented in this program are under constant revision as new sites or facilities are added. They may not contain all the potential or existing sites or facilities. The West Virginia Bureau for Public Health is not responsible for the use or interpretation of this information. Please report any inaccuracies on either the map or inventory by phoning 304-558-2981.

Glossary:

Best Management Practices (BMPs) are operational procedures used to prevent or reduce pollution.

Public Water System (PWS) is a system for the provision to the public of pipe water for human consumption, if such system has at least 15 service or regularly serves an average of at least 25 individuals daily at least 60 days of the year.

Water Quality Data is used to help assess both the potential pathogen contamination and other compliance monitoring (Nitrates) parameters associated with public water supplies.

Potential Significant Contaminant Source (PCS) is a facility or activity that stores, uses, or produces chemicals or elements, and has the potential to release contaminants identified in the state program within a source water protection area in an amount, which could contribute significantly to the contaminants of the source waters of the public water supply.





tor Public Health. The Bureau makes NO representation regarding completeness or accuracy of the data hereon. Efforts are made to verify and update the data used to generate this map. However, with data sets of this size and nature, eliminating all errors is difficult. Thus, the user assumes total responsibility for verification.

Source locations not included for reasons of security

WVAWC New River District Zone of Critical Concern WV3301046 Fayette County

0

Scale: 1:64,000 Drawn by: JEM 07/18/05 1 2





Map Key

Watershed Delineation Area



This map is provided as a public service by the West Virginia Bureau for Public Health. The Bureau makes NO representation regarding completeness or accuracy of the data hereon. Efforts are made to verify and update the data used to generate this map. However, with data sets of this size and nature, eliminating all errors is difficult. Thus, the user assumes total responsibility for verification.

Source locations not included for reasons of security

WVAWC New River District Watershed Delineation Area WV3301046 Fayette County

