State of West Virginia Source Water Assessment and Protection Program

Source Water Assessment Report

Ripley Water Department Jackson County PWSID: WV3301811



Prepared by:

West Virginia Department of Health and Human Resources Bureau for Public Health Office of Environmental Health Services Source Water Protection Unit

Date: March 2003

Surface Water Public Water Supply Systems Source Water Assessment and Protection Program (SWAPP) Susceptibility Report

Prepared by the West Virginia Bureau for	What is the Purpose of a Susceptibility Report?			
Public Health, Source	A susceptibility report identifies the most significant potential			
Water Assessment and	contaminant sources that could threaten the quality of your public water			
Protection Unit	supply. Your susceptibility ranking does not imply poor water quality. Regular water tests best reflect actual water quality. This report will be used by public water supply systems with a surface water source. In			
Date Prepared: Friday, March 14, 2003	addition, this report will enhance West Virginia's existing watershed approach to water quality improvement and protection. Table 1 provides you information on your public water supply.			

What is SWAPP?

Table 1: Public Water Supply (PWS) Information

PWS ID Number

County

Ripley Water Department

WV3301811

Community

Jackson

113 South Church St. Ripley, WV 25271

The SWAPP, established under the Safe Drinking	PWS Name
Water Act, requires every state to:	PWS Address

- Delineate the area from which a public water supply system receives its water;
- Inventory land uses within the recharge areas of all public water supplies;
- of all public water supplies;
 Assess the susceptibility of drinking water sources to contamination from these land uses; and
- Publicize the results to provide support for improved protection of sources.

The West Virginia Bureau for Public Health (WV BPH) is undertaking this task. The rankings of susceptibility of your intake (s) to potential contamination are listed in Table 2.

Facility Name	Source Name	Design Meets Regulations	Susceptibility Ranking
Ripley Water Department	Mill Creek	Yes	High

The BPH Central Office assessed the source, Ripley Water Department. A file review and field survey were used to conduct the assessment.

What is my Source Water Protection Area (SWPA)?

Unlike ground water aquifers, which have a natural protective layer above them, all surface waters are susceptible to contamination because they are exposed at the surface and lack a protective barrier from contamination. Accidental spills, releases, sudden precipitation events that result in overland runoff, or storm sewer discharges can allow pollutants to readily enter the source water and potentially

delineations.

• Watershed Delineation Area

The first type of delineation is the Watershed Delineation Area (WSDA). Figure 1 shows the extent of the WSDA, which covers approximately 134 square miles in the Middle Ohio River South Watershed. The WSDA includes the entire watershed area upstream of the intake up to the boundary of the West Virginia state border, or a topographic boundary. The perimeter of the catchment area provides the water to the water supply intake.

• Zone of Critical Concern

The second type of delineation is the Zone of Critical Concern (ZCC). Figure 2 shows the ZCC area, which covers approximately 1,596 acres. The ZCC is a corridor along streams within the WSDA that warrants a more detailed inventory and management due to its proximity to the surface intake and to the susceptibility to potential contaminants. The ZCC is calculated using a mathematical model that accounts for stream flows, gradient, and area topography. The length of the ZCC is based on a five hour time of travel. The ZCC width is 1,000 feet from each bank of the principal stream and 500 feet from each bank of the tributaries draining into the principal stream.

What is Susceptibility?

Susceptibility is a measure of your intake's potential for contamination from land uses and activities within the SWPA at concentrations that pose a concern. The purpose of the susceptibility analysis is to provide a pointer to what action a public water system should take to further define and reduce susceptibility. This may include recommendations for a more detailed inventory and assessment, monitoring work, or an indication of the type and intensity of source water and other protection activities needed.

The possibility of a release from potential contaminant sources is greatly reduced if best management practices (BMPs) are used. However, the susceptibility determination for your intake did not take into account whether BMPs are being used.

Susceptibility of a drinking water intake does not mean a customer will drink contaminated water. Water Suppliers protect drinking water by monitoring and treating water supplies, and using BMPs and source water protection measures to ensure that safe water is delivered to the tap.

How Was The Water Supply Susceptibility Determined?

Your intake (s) susceptibility is based on the following:

Resource Characterization

The purpose for conducting the Resource Characterization analysis of the delineated SWPA is to obtain an understanding of its physical, biological, chemical, and hydrological characteristics. Four resource characteristics were evaluated:

The notential for surface much off to comm

- The movement through the SWAP area; and
- The biological and chemical health of the surface water resource in the SWAP area.

• Potential for Surface Runoff to Occur

The soil types present in the watershed area and the associated soil properties have a direct influence on the potential for surface runoff to occur. As infiltration rate of soil increases, (more precipitation soaking in rather than running off) the contaminant load associated with the reduced runoff should decrease. Table 3 provides a summary of the associated soil groups.

Table 3: Summary of Soil Associations in the WSDA

Soil Associations	Soil Drainage	Topographic Setting	
Upshur Muskingum Vandalia	NA	Strongly sloping to very steep	
Moshannon Senecaville Markland	Well to moderately well drained	Nearly level	

• Ease of movement of material into the Stream System (Rate of Overland Material Transport):

The size, shape, and slope of the SWAP area have a direct influence on material transported by surface runoff. In general, the longer the overland travel distance and travel time that surface runoff has taken in order to reach a stream channel, the greater the chance it has to deposit and filter the contaminants that may occur. Table 4 provides an analysis of the size, shape, and slope.

 Table 4: Hvdrologic Setting

Size of WSDA (mi ²)	134
Shape of WSDA	Short & Wide
Stream Length (Main Stem) (mi)	11
Average Watershed Slope	10 to 30 %

• Movement of Water through the Watershed Area

A number of physical and natural factors can influence the movement of water through the SWAP area. The pattern and development of the drainage network of the SWAP area directly influence the rate of water movement. Evaluation of the hydrologic cycle will provide an indication of the amount of annual rainfall that is absorbed into the ground or becomes runoff. Table 5 summarizes the total mileage of streams contained in the WSDA, average stream gradients of the main stem, average rainfall, the nearest relevant USGS stream gauge, distance to gauge, topographic position of gauge, annual mean discharge, high flow, and low flow.

Number of Stream Miles	199
Average Stream Gradient (Main Stem)	3.6 ft/mi
Average Rainfall (in)	42
Nearest Relevant	NA
USGS Stream Gauge	
Distance to Relevant	NA
USGS Stream Gauge (mi)	
USGS Stream Gauge	NA
Topographic Position	
Annual Mean Discharge (cfs)	NA
High Flow (cfs)	NA
Low Flow (cfs)	NA

Table 5: Movement of Water

• <u>Review of Water Quality Data</u>

In order to characterize the condition of the surface water within the watershed, the available chemical and biological water quality data was reviewed. This data was collected as part of the BPH and the West Virginia Department of Environmental Protection (DEP) implementation of the federal Safe Drinking Water Act and Clean Water Act. Water quality data was evaluated to help provide direct pointers to a source of contamination and to direct the focus for additional source evaluations. Additionally, immediate source water protection efforts will be identified by this review.

Available water quality data includes test results from treated drinking water, finished water, and untreated source water (raw water) conducted by the water supplier; ambient water chemistry; biological criteria and monitoring (bacteria, macroinvertibrates and fish); and habitat evaluation. The sampling requirements for public water systems vary depending on the type of system and the federal regulated testing requirements. Therefore, a lack of water quality impacts may indicate the lack of a certain type of sampling rather than a lack of contamination.

Summary of Raw and Finished Water Quality Results from Public Water System

Water sampling conducted by the Ripley Water Department did not indicate any substantial water quality issues. Chemical constituents of concern identified via water quality testing during the past five years at the intake treatment plant include one turbidity sample above the MCL. For additional information on the finished water quality, please review the consumer confidence report for a yearly summary of the water quality.

Summary of Chemical and Biological Water Quality Results from the West Virginia DEP Middle Ohio River South Watershed-5030202

The Middle Ohio River South Watershed includes the subwatersheds draining into the Ohio River downstream of the mouth of Little Kanawha River to an including Oldtown Creek and has a watershed area of 706 square miles. In 2000, the DEP conducted biological and chemical water quality monitoring on 37 streams totaling 396.13 miles were assessed in the Middle Ohio River South watershed for the 305b report, as a requirement of the federal Clean Water Act. Of the 396.13 stream miles assessed.

but threatened, and 267.15 (67.4%) were partially supporting. Considering major and moderate/minor impacts, the principal causes of impairment in the watershed are Siltation (163.39 miles), Pesticides, PCB's and Metals (each 93.50 miles), and Habitat Alteration (non-flow) (90.93 miles). Considering both major and moderate/minor impacts, the principal sources of pollution in the watershed are Agriculture (81.77 miles), Unknown Source (80.03 miles), and Construction (29.36 miles). During this reporting cycle, 322.82 stream miles in the Middle Ohio River South watershed were monitored for toxics. Of these, only the Ohio River mainstem (93.50 miles) had elevated levels.

During this reporting cycle, the Ohio River mainstem (93.50 miles) was the only stream assessed in the watershed for Fish Consumption use. The entire reach was partially supporting due to chlordane and PCB's contamination. Within the Middle Ohio River South watershed, only the Ohio River mainstem segment is under a fish consumption advisory. This risk-based advisory was issued in May 1996 and is due to contamination by PCB's. Although PCB's, chlordane, and dioxin were all present at detectable levels in tissue samples, consumption advisories are based on the most stringent criteria, which during this reporting period, turned out to be the risk based criteria for PCB's. A commercial fishing ban on the Ohio River mainstem segment coincides with the fish consumption advisory. The Ohio River mainstem is the only watershed stream included in the current 303(d) list for PCB's, chlordane, and dioxin in fish tissue and dioxin, aluminum, and iron in the water column. The source of these pollutants is undetermined. A TMDL has not yet been completed on the stream, although one currently is in progress.

Note: This section applies to the entire watershed. Therefore, the numbers presented may not reflect conditions that exist in the portion of the watershed area specific to the plant intake.

Summary of Other Available Chemical and Biological Water Quality Data Not Available

POTENTIAL SIGNIFICANT CONTAMINANT SOURCES (PSCSs):

Inventory of Potential Significant Contaminant Sources

The purpose of providing an inventory of certain types of land uses, PSCSs, and activities within the SWAP area is to aid in reducing the risk posed to the public drinking water supply. The following subsections provide information regarding the methodology used to generate the inventories.

The inventory portion of the SWAP consists of two steps:

- The first step is the broad inventory based primarily on regulated and existing databases. The inventory consists of a general land use analysis, the identification of regulated activities in the delineated WSDAs, and an analysis of road and rail crossings adjacent to the streams in the WSDA.
- The second step is the detailed inventory of PSCSs in the ZCC. The detailed source inventory is conducted to identify PSCSs that were not captured in the broad regulated source inventory and to field verify the PSCSs in the ZCC. PSCSs located during the inventory are found on Figure 2.

A detailed risk-assessment of the PSCSs was beyond the scope of this survey because of minimal data

to make the bridge from assessment work to protective strategies. The West Virginia SWAP program can provide guidance to the decision makers and help in prioritizing the PSCSs.

Existing (primarily regulated) Database T Review

Table 6: Summary of existing (primarily regulated) PSCSs

Table 6 is a summary of existing PSCSs based on public information obtained from various federal, state, and local agencies that maintain environmental regulatory databases. These databases provide information about the regulatory status of a property and incidents

	NUMBER	PERCENT
WSDA	26	100
ZCC	10	38

involving use, storage, spilling or transportation of oil, and hazardous materials.

• Summary of the Detailed Inventory

Table 7 is a summary of the detailed inventory of PSCSs in the ZCC. The detailed source inventory was conducted to identify PSCSs that were not identified in the existing database review and to verify the location of the PSCSs within the ZCC. Additional PSCSs that were identified in detailed inventories of the ZCC consist of commercial activities (gas stations, car dealerships, dry cleaners, auto repair shops, equipment rentals, car washes, and an automobile fleet station), municipal operations (park lands,

Table 7: Summary	v of PSCSs	within	the ZCC

Potential	TOTAL	PERCENT
Contaminant	PSCSs	
Source		1.0
AGRICULTURE	2	4.9
RESIDENTIAL	0	0
MUNICIPAL	5	12.2
COMMERCIAL	31	75.6
INDUSTRIAL	3	7.3

highways, landfills, and a demolition store), and industrial operations. Of these PSCSs, some of the industrial sources may have large volumes of potential contaminant stored.

• Transportation Network

A summary of the transportation network is shown in Table 8. This information can be used to aid in planning for transportation related accidents that could result in contamination of the source water in the delineated WSDA. Table 9 is a summary of the transportation network stream crossings in the WSDA. Please note that miles of train tracks could be less due to decommissioning of tracks.

	Within 100 feet of stream	Total
Miles of	0.26	9.84
Interstate		
Miles of	0.18	13.33
Primary		
Miles of	0.06	1.23
Secondary		
Miles of	0	0
Train		
Tracks		

Table 8: Transportation Network Summary for WSDA

Table 9: Transportation Network Stream Crossings in the WSDA

	Train Tracks	Interstate	Primary Roads	Secondary Roads
Number of Stream Crossings	0	5	5	1

General Land Use

The general land use analysis will provide an indication of which land uses predominate throughout the SWAP area, near the intake, or adjacent to the rivers, streams, lakes, and reservoirs. The land use in the SWAP area is shown in Table 10.

LAND USE	WSDA (Acres)	WSDA % of Total	ZCC Area (Acres)	ZCC % of Total
Shrub Land	205	0.24	0	0
Woodland	63,759	74.12	403	25.35
Water	231	0.27	15	0.94
Roads	131	0.15	0	0
Power lines	4	0	0	0
Urban	1315	1.53	231	14.53
Agriculture	19,921	23.16	932	58.62
Barren	285	0.33	5	0.31
Wetland	176	0.20	4	0.25

Table 10: General Land Use

SWAPP Area Assessment and Protection Activities

Analysis of the Resource Characterization and potential significant contaminant sources of the SWAP area for the Ripley Water Department indicates that the water supply is susceptible to possible future contamination based on the following:

- ✓ The 11 stream crossings provide the opportunity for an accidental release/spill of material to get directly into the stream drainage network. Source water protection efforts should be directed toward the establishment of an effective and efficient emergency response plan if one does not currently exist.
- ✓ Current land use practices may have an adverse impact on the ecological health of the Middle Ohio River South Watershed. Of the 396.13 stream miles assessed in the DEP 305(b) report; only 91.89 (23.2%) were fully supporting their overall designated uses. In addition, the health of Mill Creek may be impacted by a number of regulated and unregulated point and non-point sources in the ZCC and WSDA.

Recommendations:

- ✓ Protection efforts should focus on the collection of additional information on the point and nonpoint sources present to evaluate the risk;
- ✓ Work with the Department of Health and Human Resources, other state agencies and local officials to make sure your intake is included in local regulations and inspections efforts;
- ✓ Restrict access to the intake area and post the area with Drinking Water Protection Area signs;
- ✓ Address any biological contaminant issues; and
- ✓ Protection options need to be actively considered to further evaluate and manage all potential contaminant sources and the Ripley Water Department should place a high priority on protecting its supply source.

NEXT STEP – SWAP Protection Plan

The next step in source water protection planning is to prepare a SWAP protection plan. The SWAP protection plan incorporates this source water delineation assessment report and three additional sections: Contingency Planning, Alternative Sources, and Management Planning.

Contingency Planning

A contingency plan documents the system's planned response to interruption of the source water supply.

Alternative Sources

Information pertaining to alternative water sources focusing on long-term source replacement should the system be required to develop a new source of water due to contamination (or other reasons). This section outlines the most likely sources that can be used as an alternate water source.

Management Planning

Management planning is the most important element of SWAP. The management plan identifies specific activities that will be pursued by the system to protect their water resources. The system will benefit by taking a proactive approach to source water protection in their watersheds. It is anticipated that most of the management effort will focus on coordination with government agencies and periodic surveys of the watersheds. It may be necessary to conduct a limited number of special studies to determine actual risk and consequences for selected contaminant sources. This information may be needed before decisions can be made on management activities.

Need additional information?

Additional information or sources of information can be obtained by calling or visiting the BPH web site at www.wvdhhr.org/bph/swap or phoning 304-558-2981.

Disclaimer - The coverages presented in this program are under constant revision as new sites or facilities are added. They may not contain all the potential or existing sites or facilities. The West Virginia Bureau for Public Health is not responsible for the use or interpretation of this information. Please report any inaccuracies on either the map or

Glossary:

Best Management Practices (BMPs) are operational procedures used to prevent or reduce pollution.

Public Water System (PWS) is a system for the provision to the public of pipe water for human consumption, if such system has at least 15 service or regularly serves an average of at least 25 individuals daily at least 60 days of the year.

Water Quality Data is used to help assess both the potential pathogen contamination and other compliance monitoring (Nitrates) parameters associated with public water supplies.

Potential Significant Contaminant Source (PSCS) is a facility or activity that stores, uses, or produces chemicals or elements, and has the potential to release contaminants identified in the state program within a source water protection area in an amount, which could contribute significantly to the contaminants of the source waters of the public water supply.







Map Key

Watershed Delineation Area



This map is provided as a public service by the West Virginia Bureau for Public Health. The Bureau makes NO representation regarding completeness or accuracy of the data hereon. Efforts are made to verify and update the data used to generate this map. However, with data sets of this size and nature, eliminating all errors is difficult. Thus, the user assumes total responsibility for verification.

Source locations not included for reasons of security

0

City of Ripley Watershed Delineation Area WV3301811 Jackson County

Scale: 1:140,000 Drawn by: JEM 09/08/05 Miles 2 4